

Brenda Solar Energy Zone (SEZ)
SEZ-Specific Design Features

(from Solar PEIS ROD, Section A.4.2)

- *Water Resources:* Groundwater analyses suggest that full build-out of wet-cooled technologies is not feasible; for mixed-technology development scenarios, any proposed wet-cooled projects should utilize water conservation practices.
- *Acoustic Environment:* Because of the proximity of the proposed Brenda SEZ to nearby residences and the Plomosa SRMA and the relatively high noise levels around the SEZ due to U.S. 60, refined modeling would be warranted along with background noise measurements during project-specific assessments.